

## Type test Certificate of short-circuit performance

### **Q.T.C. Transformer Co. Ltd.**

Rayong, Thailand

has successfully passed the type test sequence on a

### **Oil-immersed distribution transformer**

Type: 167 kVA

Rating: 167 kVA – 22 kV  $\pm 2 \times 2,5\%$  // 230 / 460 V – 1 phase – 50 Hz

The test object passed the specification of test duties of

### **IEC 60076-5**

The test results are recorded in Certificate No.

### **54-07**

This Certificate is only valid for LV windings connected in parallel.

This Certificate is issued on 25 September 2007

KEMA Nederland B.V.



P.G.A. Bus  
KEMA T&D Testing Services  
Managing Director

Copyright © KEMA Nederland B.V.  
Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has qualified or approved any apparatus other than the apparatus tested.

